

06/23/17



CEDRONI ASSOCIATES INC.
General Contractors

5639 Auburn Rd.
Utica, MI 48317

Phone (586) 254-7778
Fax (586) 254-4517

TITLE: Column Dimension

REQUEST FOR INFORMATION

NO. 1

PROJECT: Ford Field Comfort Station

DATE: 06/15/2017

TO: Attn: Eric Stockwell
NSA Architects
23761 Research Drive
Farmington Hills, Michigan 48335

STARTED:

COMPLETED:

REQUIRED:

REQUEST:

On Drawing S1.0, as well as Drawing A3.0, the column dimension is shown to be 2'-0" x 2'-0".

On Drawing A4.0, Detail 10 shows the column dimension to be 2'-8" x 2'-8".

Please clarify what the correct dimension for the column should be.

ANSWER:

*CMU COLUMN DIMENSION SHOULD BE 2'-0" X 2'-0"
ON DETAIL 10 ON A4.0.*

Requested By: Cedroni Associates, Inc.

Date: 06/15/2017

Signed: _____
Brian M. Lundberg