



**CEDRONI ASSOCIATES INC.**  
**General Contractors**

5639 Auburn Rd.  
Utica, MI 48317

Phone (586) 254-7778  
Fax (586) 254-4517

**TITLE:** Rigid Foam Insulation  
**PROJECT:** Ford Field Comfort Station

**REQUEST FOR INFORMATION**  
**NO. 6**  
**DATE:** 04/10/2018

**TO:** Attn: Eric Stockwell  
NSA Architects  
23761 Research Drive  
Farmington Hills, Michigan 48335

**STARTED:**  
**COMPLETED:**  
**REQUIRED:**

**RECEIVED**

**4/10/2018**



**REQUEST:**

Will rigid foam insulation be acceptable as opposed to the spray-on foam currently specified?

**ANSWER:**

*CLOSED CELL  
RIGID FOAM INSULATION IS ACCEPTABLE*  
*- SEAL EDGES*  
*- PROVIDE R VALUE EQUAL TO SPRAY-ON FOAM  
SPECIFIED*  
*- COORDINATE AIR BARRIER INSTALLATION*

**Requested By:** Cedroni Associates, Inc.

**Date:** 04/10/2018

**Signed:** \_\_\_\_\_

Brian M. Lundberg