



CEDRONI ASSOCIATES INC.
General Contractors

5639 Auburn Rd.
Utica, MI 48317

Phone (586) 254-7778
Fax (586) 254-4517

TITLE: Electrical Outlet Heights
PROJECT: Ford Field Comfort Station

REQUEST FOR INFORMATION
NO. 10
DATE: 05/08/2018

TO: Attn: Eric Stockwell
NSA Architects
23761 Research Drive
Farmington Hills, Michigan 48335

STARTED:
COMPLETED:
REQUIRED:

RECEIVED

5/8/2018



REQUEST:

What is the required height of the electrical wall outlets? Are they to be mounted in the exterior brick or the siding? Please advise.

ANSWER:

18" AFF., FLUSH MOUNTED IN THE EXTERIOR BRICK.

J. Czuchra, NSA
5/15/2018

Requested By: Cedroni Associates, Inc.

Date: 05/08/2018

Signed:

Brian M. Lundberg