



CEDRONI ASSOCIATES INC.
General Contractors

5639 Auburn Rd.
Utica, MI 48317

Phone (586) 254-7778
Fax (586) 254-4517

TITLE: Sidewalk Slope
PROJECT: Ford Field Comfort Station

REQUEST FOR INFORMATION
NO. 12
DATE: 06/01/2018

TO: Attn: Eric Stockwell
NSA Architects
23761 Research Drive
Farmington Hills, Michigan 48335

STARTED:
COMPLETED:
REQUIRED:

RECEIVED
6/1/2018



REQUEST:

The sidewalk connecting the pavilion to the parking lot has an elevation drop of approximately 4 feet across a distance of roughly 25 feet. This pitch seems to be way too steep as drawn. Will stairs or a new layout be required? Please advise.

ANSWER:

*THE SIDEWALK WILL REQUIRE STAIRS.
A ~~REVISED~~ REVISED LAYOUT WILL BE ISSUED
AS BULLETIN NO. 2.*

[Handwritten Signature] 6/11/18

Requested By: Cedroni Associates, Inc.

Date: 06/01/2018

Signed: _____
Brian M. Lundberg