

ADDENDUM NO. 2

DATE: November 1, 2019

PROJECT: Niles Barnard Renovation Project

OWNER: The City of Troy

BID DATE: Thursday, November 7, 2019, at 10:00 AM E.S.T.

The following shall be incorporated into the Contract Documents dated **September 30, 2019**.

GENERAL

See attached RFI Log for RFI's and responses.

PROJECT MANUAL

07 25 00 – WEATHER BARRIERS – NOT ISSUED

Revised section 2.1.A. Manufacturers to read:

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. DuPont Safety and Construction; Tyvek DrainWrap
2. The Henry Company; WeatherSmart Drainable
3. TYPAR; Drainable Wrap
4. Kimberly-Clark Worldwide Inc, BLOCK-IT House Wrap.

Added 2.1.B.9. Drainage Efficiency: 94% to ASTM D2273.

End of Addendum No. 2

Niles Barnard House

0128-18-0020

Bidding Request for Information Log

Bidding Request For Information Log

Owner:

City of Troy, Michigan
500 West Big Beaver
Troy, MI 48084
Tel: (248) 524-3300

Architect/Engineer:



34000 Plymouth Road
Livonia, MI 48150
Tel: 734.522.6711
Fax: 734.522.6427
www.ohm-advisors.com

Date Printed: 10/31/2019

<i>RFI.#</i>	<i>Description:</i>	<i>Date Rec'd.</i>	<i>Date of Response</i>	<i>Action:</i>
RFI-1	I have been advised that the floor box specified on the plans is not suited for wood floors. (Sheet E0.2 – Floor Service Fitting Assembly Schedule) An alternate is attached. Please advise.	10/28/19	10/28/19	880W is the correct box model number. Description noted in schedule correct, calling for wood floor installation.
RFI-2	With these 2 projects being due on the same day/time would the city entertain moving the bid to 2 PM instead of 10 AM	10/30/19	10/30/19	The bid opening day and time is not changing.
RFI-3				
RFI-4				
RFI-5				
RFI-6				
RFI-7				
RFI-8				